

PL01 : PHẠM VI CÔNG VIỆC GT-2025-217 MUA SẴM VẬT TƯ DỰ PHÒNG BẮT BUỘC THIẾT BỊ ĐO LƯỜNG VÀ ĐIỀU KHIỂN NĂM 2025 ĐỢT 1 (SAU ĐIỀU CHỈNH)- NHÀ MÁY NHIỆT ĐIỆN THÁI BÌNH 2
(Đính kèm công văn số 1756/NMĐTB2-TM ngày 06/10/2026)

STT	Tên hàng hóa/ dịch vụ	Thông số kỹ thuật/ Yêu cầu kỹ thuật	Nhà sản xuất, xuất xứ	ĐVT	Khối lượng	Đơn giá trước thuế	Thành tiền trước thuế
					Nhu cầu mua sắm		
1	Flame scanner	DSF-2010-MB 1. Type: Iscan 2 2. P/N: 2653-271-62 3. Spectrum response: 500 nm ~1700nm 4. Power supply: 24VDC±10% 5. Operating Current : ≤200mADC 6. Power Dissipation : ≤5W 7. Electrical connection: 12-core, rotating quick-fit connector 8. Relay Output : - Flame Relay, SPST (ON) - Alarm Relay, SPST (ON) - Contact Capacity MAX : 3A, 250VAC (Resistive Load 9. Analog Output : (4~20) mA DC, Maximum load:750ohm 10. Status display: 8-digit digital tube and 4-digit LED display 11. Cable specification: 12-core color, flame retardant, low smoke, shielded cablek. Communication : Mode: RS485 (controllable type)	LKHZ/China	cái	15		

